



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8616CS0530

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Distributor <i>Vertreiber</i>	FIP Formatura Iniezione Polimeri SpA Pian di Parata, I-16015 Casella (GE)
Product Category <i>Produktart</i>	plastic fittings and compression fittings: plastic compression fitting for PE pipes (8616)
Product Description <i>Produktbezeichnung</i>	plastic compression fitting made of PP-B for PE-HD pipes for the drinking water supply
Model <i>Modell</i>	MAGNUM 3G
Test Reports <i>Prüfberichte</i>	type testing: 20180323 from 23.03.2017 (TTR) KTW testing: KR 075/17 from 18.07.2017 (TZW) hygienic testing: MO 134/15 from 02.12.2015 (TZW) UBA-Guideline: KA 0414/17 from 28.02.2018 (TZW) hygienic testing: MO 006/13 from 09.08.2016 (TZW)
Test Basis <i>Prüfgrundlagen</i>	DVGW GW 335-B3/(P) (01.09.2011) UBA KTW (07.03.2016) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	23.03.2022 / 17-0068-WNE

70028-04-A-DE

09.05.2018 GI B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
MAGNUM 3G	nominal diameter: 20 mm	
MAGNUM 3G	nominal diameter: 25 mm	
MAGNUM 3G	nominal diameter: 32 mm	
MAGNUM 3G	nominal diameter: 40 mm	
MAGNUM 3G	nominal diameter: 50 mm	
MAGNUM 3G	nominal diameter: 63 mm	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

nominal pressure rating: PN 16

Self-sealing threaded connections are not subject of this certification.